

TECHNICAL SHEET

Sir Safety System S.p.A. Single-member company Wholly-owned subsidiary of Sir Holding Srl Via dei Fornaciai, 9 - Santa Maria degli Angeli

06081 Assisi - Perugia - Italy Tel.+39 075.8043737 - Fax +39 075.8048686 VAT Nr. IT 03359340548 Viale Europa 74 20090 Cusago Milano Tel. +39 02.90394575 Fax +39 02.90394441

export@sirsafety.com www.sirsafety.com

Quality Management System Certificate UNI EN ISO 9001:2015

Name: ELECTRO GLOVE CLASS 0

Code: MA1814E0

MA18 SPECIAL PROTECTION GLOVES

Description

Dielectric glove Class 0

Length: 36 cm

Thickness: mm 1,0 (tolerance +0,6) in Natural Latex

Insulation: 5.000 V Proof test voltage: 5 kV Withstand voltage: 1,0 kV

Supplied in a special polyethylene sealed case.

The product has been designed and manufactured to comply with Regulation (EU) 2016/425 and subsequent amendments.



Category

Ш

Colours YELLOW

Quantity/Carton

EC Standards

IEC 60903

A

Acid. Oil. Ozone:R

Resistant to very low temperatures:C

Important Information

Available Sizes

8 - 11

Protection against contact with voltage-carrying parts under voltage.

Make sure the garment is in good condition, undamaged and clean before use. Once you become aware of a damage, you should immediately replace it.

We recommend six-monthly voltage test.

Store the gloves in their original sealed case, in a dry place far from the light, at a temperature between Í 🛱 » C.

If gloves become soiled with sticky substances or dyes, they shall be rubbed with suitable solvents, without brushes or abrasive paper. Do not use naphtha, gasoline, liquid paraffin, toluene, xylene, etc. Then wash with water at a temperature below G » C and soap and dry thoroughly.

Storage and cleaning

Data retrieval failed for the subreport,

Dexterity