



SAFETY SYSTEM®
YOUR PROTECTOR

Sir Safety System S.p.A. Single-member company
Wholly-owned subsidiary of Sir Holding Srl
Via dei Fornaciai, 9 - Santa Maria degli Angeli
06081 Assisi - Perugia - Italy
Tel.+39 075.8043737 - Fax +39 075.8048686

VAT Nr. IT 03359340548
Viale Europa 74
20090 Cusago Milano
Tel. +39 02.90394575
Fax +39 02.90394441

TECHNICAL SHEET

export@sirsafety.com
www.sirsafety.com

Quality Management
System Certificate
UNI EN ISO 9001:2015

Name: ELECTRO GLOVE CLASS 2	Code: MA1816E0	MA18 SPECIAL PROTECTION GLOVES
------------------------------------	-----------------------	---------------------------------------

Description


Dielectric glove Class 2
Length: 36 cm.
Thickness: mm 2,3 (tolerance +0,6) in Natural Latex.
Insulation: 20.000 V
Proof test voltage: 20 kV
Withstand voltage: 17 kV

Supplied in a special polyethylene sealed case.

The product has been designed and manufactured to comply with Regulation (EU) 2016/425 and subsequent amendments.



Category III	Colours YELLOW	Available Sizes 8 - 11
------------------------	--------------------------	----------------------------------

Quantity/Carton 1	EC Standards IEC 60903  Acid, Oil, Ozone:R Resistant to very low temperatures:C	Important Information Protection against contact with voltage-carrying parts under voltage. Make sure the garment is in good condition, undamaged and clean before use. Once you become aware of a damage, you should immediately replace it. We recommend six-monthly voltage test. Store the gloves in their original sealed case, in a dry place far from the light, at a temperature between -20°C » $+5^{\circ}\text{C}$. If gloves become soiled with sticky substances or dyes, they shall be rubbed with suitable solvents, without brushes or abrasive paper. Do not use naphtha, gasoline, liquid paraffin, toluene, xylene, etc. Then wash with water at a temperature below 60°C and soap and dry thoroughly.
Dexterity		Storage and cleaning Data retrieval failed for the subreport,